

Receipt No. 1138 Dated 22/8/2020

M. N. (u)
f. Behadur (u)

Signature
Principal

FORM 'H' Signature
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/2020/School/198

Dated: 19/06/2020

FIRE SAFETY CERTIFICATE

Certified that the building of D.A.V. Public School Located at Pushpanjali Enclave, Pitampura Delhi.110034, in a building comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. F-6/DFS/MS/School/2017/WZ/245 Dated 22/02/2017. The premises was re inspected by the officers concerned of this department on 16-03-2020 in the presence of Mrs. Rashmi Raj Biswal (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01-03-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 19/6/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/06/2020 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal, D.A.V. Public School Pushpanjali Enclave, Pitampura Delhi.110034.
2. Directorate of Education Old Secretariat Delhi - 110054.
3. The Commissioner, North Delhi Municipal Corporation, Civic Centre, Minto Road, New Delhi -110002, to check the addition/alteration/illegal construction if any in the premises.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. Three side open sun/ Rain shed has been seen at 1/4th portion of the terrace it must not be used for any purpose

Rashmi Raj Biswal

PRINCIPAL
D.A.V. PUBLIC SCHOOL
Pushpanjali Enclave,
Pitampura, Delhi-34